New Mexico Regulation and Licensing Department
CONSTRUCTION INDUSTRIES DIVISION
2550 Cerrillos Road ▪ Santa Fe, NM 87505 ▪ (505) 476-4700 ▪ Fax (505) 476-4685
5200 Oakland Ave. NE ▪ Albuquerque, NM 87113 ▪ (505) 222-9800 ▪ Fax (505) 765-5670
505 S. Main St., Suite 150 ▪ Las Cruces, NM 88004 ▪ (575) 524-6320 ▪ Fax (575) 524-6319
www.rld.state.nm.us/cid

ELECTRICAL PLAN REVIEW CHECK LIST

To:		Tracking #	
Job:		Phone:	
Date:		Email:	

The submitted construction drawings lack the items indicated below, please address & return.

	Item:	Description:	Reference:
	1.	Professional Seal Requirement (Single Seal)	NMAC 14.5.2.10 B, C & K
	2.	Professional Seal Requirement (Multiple Seal)	NMAC 14.5.2.10 B, C & K
	3.	One Line Riser Diagram	NMAC 14.5.2.10 A, H & K
	4.	Electrical Site Plan	NMAC 14.5.2.10 A, H & K
	5.	Power Plan	NMAC 14.5.2.10 A & H & K
	6.	Lighting Plan	NMAC 14.5.2.10 A, H & K
	7.	Load Calculations	NMAC 14.5.2.10 A, H & K; NEC 220.1
	8.	Fault Current Calculations	NMAC 14.5.2.10 A, H & K; NEC 110.10
	9.	Energy Calculations	NMAC 14.5.2.10 A & H; NMEC 14.10.4.16
	10.	Overcurrent Protection	NEC 210.20, NEC 240.4
	11.	Disconnect Size, Location	NEC/NMEC 225.32, NEC/NMEC 230.70
	12.	Conductors	NEC 310.15
	13.	Grounding Conductors	NEC 250.66. NEC 250.122
	14.	Grounding Electrode System	NEC/NMEC 250.50
	15.	Wiring Method	NEC 110.8, NEC 300.1
	16.	Panel Directory	NEC 408.4
	17.	Special Occupancies	NEC Chapter 5
	18.	Other:	
	19.	Other:	

Comments:

Contact:

Plans Examiner:		Approved, no exceptions	
Phone:		Approved, exceptions as noted	
Fax:		Hold, additional information required	
Email:		Rejected, resubmit	

Please submit the requested information to the plans examiner listed above. If you have any questions, please contact the plans examiner or the Electrical Bureau, Construction Industries Division at 505.476.4679.